

**City of Montebello**  
**Department of Public Works**  
**Engineering Division**

**Date:** 3-30-2017

**To:** Danilo Batson, Assistant City Manager  
And Attendees at the Pre Bid Meeting

**From:** Sam Kouri

**Subject:** CP 845. Video Sewers Project  
RFI's from the Pre Bid Meeting

1. **What manholes are to be flow-monitored?** *The Contractor will submit a schedule prior to starting work of MH's to be monitored. The required maximum interval between manholes will be 1,000'.*
2. *The 2-man cleaning crew does not have to be present during videoing of sewer*
3. *All waste shall be disposed of legally by the Contractor and not at the City Yard.*
4. **Can high-flow manholes be videoed at night?** *The contractor has the option of videoing sewers at night except in residential areas. Sewer cleaning will be done during the day in all cases.*
5. **Are public notices required for this project?** *No*
6. *The cost for sewer cleaning is included in the cost of other items*
7. *A Sewer Map is attached.*